

ADDENDUM 1

CITY OF FARGO TRANSIT DEPARTMENT (MATBUS)

BUS SHELTER RFP

10.4.18

1. **Is it possible to request extensions on the lead time if required once an order is placed and the drawings are approved?**
 - Lead times will be agreed upon after completion of the order and the drawings are approved. If the vendor is unable to supply the product within 75 days from the approval, the vendor may request a one (1) time exception with a new delivery date no later than 140 days from completion of the order and approved drawings.
2. **Can a substitute be used for the color/finish?**
 - Yes, as long as the substitute is blue and anti-graffiti. A sample of the substituted color must be sent with your proposal.

Further clarification: the substitute must be a blue that is close to the dark/sapphire blue requested in RFP. In addition, the finish must be anti-graffiti and powder coated. The sample of the proposed substitute must be sent with the proposal.
3. **The color specification would indicate both an anodized and powder coat finish with anti-graffiti protection. We would propose to closely match the Sapphire Blue in a Super Durable powder coat finish with anti-graffiti clear coat. Is that acceptable?**
 - Please refer to the response in #2 above. The sample of your proposed substitute must be sent with the proposal.
4. **For the shelter design, are the end walls to be full panels or are the shelters to be cantilevered with ½ end walls?**
 - The end walls are to be full panels.

5. **For the Ad Box illumination, are you looking for both a grid tied and solar powered option and, if solar, is 6 hours after dusk acceptable?**
 - The Ad Box illumination for either the grid tied or the solar powered option is to be for 8 hours beyond dusk year round.
6. **For the solar lighting system, you mention 8 hours in the winter months—do you want a dusk to dawn system that dims during part of that time in the winter?**
 - The solar lighting system should run full power/fully lit, for 8 hours after dusk year round (no dimming during that time).
7. **Our system would be UL compliant, is that something that can be required?**
 - We are not going to require UL compliant certification for these shelters.
8. **Additionally, our system offers 5-7 days of autonomy, is there a requirement for that?**
 - There is not a requirement for system autonomy.
9. **Is there a minimum light level requirement for the security lighting?**
 - A minimum light level requirement for the security lighting has not been established, however, the proposal should include recommended lighting settings.